

Anacon, Inc.

Date: 15-Jan-08

CLIENT: Texas Water Development Board
 Lab Order: 0710088
 Project:
 Lab ID: 0710088-002

Client Sample ID: 10-46-704 (214)
 Collection Date: 10/2/2007 10:45:00 AM

Matrix: WATER

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
ICP-MS METALS		E200.8				Analyst: GL
Aluminum	3.99	0.700		µg/L	1	10/19/2007 1:16:00 PM
Antimony	ND	0.836		µg/L	1	10/19/2007 1:16:00 PM
Arsenic	1.78	0.733		µg/L	1	10/19/2007 1:16:00 PM
Barium	95.9	0.614		µg/L	1	10/19/2007 1:16:00 PM
Beryllium	ND	0.835		µg/L	1	10/19/2007 1:16:00 PM
Boron	156	3.00		µg/L	1	10/19/2007 1:16:00 PM
Cadmium	ND	0.654		µg/L	1	10/19/2007 1:16:00 PM
Chromium	ND	1.17		µg/L	1	10/19/2007 1:16:00 PM
Cobalt	ND	0.593		µg/L	1	10/19/2007 1:16:00 PM
Copper	1.50	0.904		µg/L	1	10/19/2007 1:16:00 PM
Iron	20.0	0.739		µg/L	1	10/19/2007 1:16:00 PM
Lead	ND	0.843		µg/L	1	10/19/2007 1:16:00 PM
Lithium	65.1	3.00		µg/L	1	10/19/2007 1:16:00 PM
Manganese	0.271	0.137		µg/L	1	10/19/2007 1:16:00 PM
Mercury	ND	1.14		µg/L	1	10/19/2007 1:16:00 PM
Molybdenum	3.29	0.956		µg/L	1	10/19/2007 1:16:00 PM
Selenium	8.86	0.989		µg/L	1	10/19/2007 1:16:00 PM
Silver	ND	0.886		µg/L	1	10/19/2007 1:16:00 PM
Strontium	1200	3.00		µg/L	1	10/19/2007 1:16:00 PM
Thallium	ND	0.363		µg/L	1	10/19/2007 1:16:00 PM
Vanadium	13.6	2.55		µg/L	1	10/19/2007 1:16:00 PM
Zinc	31.6	0.679		µg/L	1	10/19/2007 1:16:00 PM
ICP-MS METALS MODIFIED		E200.8				Analyst: HN
Calcium	59.5	0.04		mg/L	1	10/16/2007 11:29:00 AM
Magnesium	37.0	0.13		mg/L	1	10/16/2007 11:29:00 AM
Potassium	7.33	0.17		mg/L	1	10/16/2007 11:29:00 AM
Sodium	39.5	0.05		mg/L	1	10/16/2007 11:29:00 AM
SILICA AS SIO2		E200.8				Analyst: HN
Silica	27	0.050		mg/L	1	10/19/2007
ANIONS BY ION CHROMATOGRAPHY		E300				Analyst: KK
Bromide	0.770	0.100		mg/L	1	10/10/2007
Chloride	74.7	0.500		mg/L	1	10/15/2007
Fluoride	0.992	0.500		mg/L	1	10/10/2007
Nitrogen, Nitrate+Nitrite (As N)	4.91	0.150		mg/L	1	10/10/2007
Sulfate	59.5	0.500		mg/L	1	10/15/2007
ANION / CATION BALANCE		A/C BALANCE				Analyst: MK
Anion / Cation Balance	-0.22	5.00		%	1	10/31/2007
ALKALINITY		M2320 B				Analyst: SB

Qualifiers:
 ND - Not Detected at the Reporting Limit
 J - Analyte detected below quantitation limits
 B - Analyte detected in the associated Method Blank
 * - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits
 R - RPD outside accepted recovery limits
 E - Value above quantitation range

Anacon, Inc.

Date: 15-Jan-08

CLIENT: Texas Water Development Board
Lab Order: 0710088
Project:
Lab ID: 0710088-002

Client Sample ID: 10-46-704 (214)
Collection Date: 10/2/2007 10:45:00 AM

Matrix: WATER

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
ALKALINITY			M2320 B			Analyst: SB
Alkalinity, P	ND	20.0		mg/L	1	10/10/2007
Alkalinity, Total	285	20.0		mg/L	1	10/10/2007

Qualifiers:

ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range