

**Anacon, Inc.**

Date: 03-Jul-08

CLIENT: Texas Water Development Board  
 Lab Order: 0805006  
 Project:  
 Lab ID: 0805006-007

Client Sample ID: 28-35-603 (007)  
 Collection Date: 4/23/2008 2:40:00 PM

Matrix: WATER

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>ICP-MS METALS</b>		<b>E200.8</b>				Analyst: <b>HN</b>
Aluminum	7.17	0.700		µg/L	1	6/17/2008 6:46:00 PM
Antimony	ND	0.836		µg/L	1	6/17/2008 6:46:00 PM
Arsenic	28.6	0.733		µg/L	1	6/17/2008 6:46:00 PM
Barium	28.3	0.614		µg/L	1	6/17/2008 6:46:00 PM
Beryllium	ND	0.835		µg/L	1	6/17/2008 6:46:00 PM
Boron	951	3.00		µg/L	1	6/17/2008 6:46:00 PM
Cadmium	ND	0.654		µg/L	1	6/17/2008 6:46:00 PM
Chromium	ND	1.17		µg/L	1	6/17/2008 6:46:00 PM
Cobalt	ND	0.593		µg/L	1	6/17/2008 6:46:00 PM
Copper	3.43	0.904		µg/L	1	6/17/2008 6:46:00 PM
Iron	52.9	0.739		µg/L	1	6/17/2008 6:46:00 PM
Lead	ND	0.843		µg/L	1	6/17/2008 6:46:00 PM
Lithium	209	3.00		µg/L	1	6/17/2008 6:46:00 PM
Manganese	0.314	0.137		µg/L	1	6/17/2008 6:46:00 PM
Mercury	ND	1.14		µg/L	1	6/17/2008 6:46:00 PM
Molybdenum	10.4	0.956		µg/L	1	6/17/2008 6:46:00 PM
Selenium	25.0	0.989		µg/L	1	6/17/2008 6:46:00 PM
Silver	ND	0.886		µg/L	1	6/17/2008 6:46:00 PM
Strontium	14100	3.00		µg/L	1	6/17/2008 6:46:00 PM
Thallium	ND	0.363		µg/L	1	6/17/2008 6:46:00 PM
Uranium	17.2	1.00		µg/L	1	6/17/2008 6:46:00 PM
Vanadium	212	2.55		µg/L	1	6/17/2008 6:46:00 PM
Zinc	169	0.679		µg/L	1	6/17/2008 6:46:00 PM
<b>ICP-MS METALS MODIFIED</b>		<b>E200.8</b>				Analyst: <b>HN</b>
Calcium	159	0.04		mg/L	1	6/18/2008 2:49:00 PM
Magnesium	95.8	0.13		mg/L	1	6/18/2008 2:49:00 PM
Potassium	13.0	0.17		mg/L	1	6/18/2008 2:49:00 PM
Sodium	232	0.05		mg/L	1	6/18/2008 2:49:00 PM
<b>SILICA AS SiO2</b>		<b>E200.8</b>				Analyst: <b>HN</b>
Silica	130	0.30		mg/L	1	6/18/2008 2:49:00 PM
<b>ANIONS BY ION CHROMATOGRAPHY</b>		<b>E300</b>				Analyst: <b>KK</b>
Bromide	2.86	0.100		mg/L	1	5/20/2008
Chloride	247	0.500		mg/L	1	5/19/2008
Fluoride	7.53	0.500		mg/L	1	5/20/2008
Nitrogen, Nitrate (As N)	44.0	0.150		mg/L	1	5/16/2008
Nitrogen, Nitrate / Nitrite (as N)	44.0	0.150		mg/L	1	5/16/2008
Sulfate	269	0.500		mg/L	1	5/19/2008
<b>ANION / CATION BALANCE</b>		<b>A/C BALANCE</b>				Analyst: <b>MK</b>
Anion / Cation Balance	-0.14	5.00		%	1	6/18/2008

**Qualifiers:**  
 ND - Not Detected at the Reporting Limit  
 J - Analyte detected below quantitation limits  
 B - Analyte detected in the associated Method Blank  
 \* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits  
 R - RPD outside accepted recovery limits  
 E - Value above quantitation range

**Anacon, Inc.**

**Date:** 03-Jul-08

**CLIENT:** Texas Water Development Board  
**Lab Order:** 0805006  
**Project:**  
**Lab ID:** 0805006-007

**Client Sample ID:** 28-35-603 (007)  
**Collection Date:** 4/23/2008 2:40:00 PM

**Matrix:** WATER

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
<b>ALKALINITY</b>			<b>M2320 B</b>			Analyst: <b>SB</b>
Alkalinity, P (as CaCO3)	ND	20.0		mg/L	1	5/5/2008
Alkalinity, Total (as CaCO3)	315	20.0		mg/L	1	5/5/2008

**Qualifiers:** ND - Not Detected at the Reporting Limit  
J - Analyte detected below quantitation limits  
B - Analyte detected in the associated Method Blank  
\* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits  
R - RPD outside accepted recovery limits  
E - Value above quantitation range